

GENERAL NOTES

DO NOT SCALE THIS DRAWING. WORK ONLY TO FIGURED DIMENSIONS.

SPECIFICATION.

- 2. FOR ALL RELEVANT NOTES, REFER TO STRUCTURAL AND CIVIL ENGINEERING PERFORMANCE
 - 3. ANY DISCREPANCIES ARE TO BE REPORTED TO PINNACLE CONSULTING ENGINEERS IMMEDIATELY.
 - 4. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT ENGINEERS, ARCHITECTS AND
 - SUB-CONTRACTORS DRAWINGS AND DETAILS.
 - 6. THIS DRAWING IS NOT TO BE USED FOR CONSTRUCTION PURPOSES UNLESS EXPRESSLY STATED.
 - EXISTING SITE AND LEVEL INFORMATION TAKEN FROM LAND SURVEYS TOPOGRAPHICAL SURVEY DRAWING D1728F2D DATED 04/10/06.
 - 8. THIS DRAWING HAS BEEN PREPARED USING THE PROPOSED SITE LAYOUT FROM DAVEY + SMITH ARCHITECTS DRAWING IP00 DATED 16/08/24.

LEGEND

EXISTING BULK WATERMAIN

EXISTING WATERMAIN

PROPOSED 150mm HDPE,

PROPOSED 100mm HDPE, PE100, SDR17 WATERMAIN

BOUNDARY BOX AND 25mm OD PE80 SERVICE CONNECTION AS PER IRISH WATER STANDARD STD-W-03

BOUNDARY BOX AND 32mm OD PE80 SERVICE CONNECTION AS PER IRISH WATER STANDARD STD-W-03 BOUNDARY BOX AND 65mm OD PE80 SERVICE CONNECTION AS PER

IRISH WATER STANDARD STD-W-03 RETAINING WALL

FFL 100.200 PROPOSED FFL SLUICE VALVES AS PER IRISH WATER STANDARD DETAIL STD-W-14/15

AIR VALVE AS PER IRISH WATER STANDARD DETAIL STD-W-20/22

SCOUR VALVE AS PER IRISH WATER STANDARD DETAIL STD-W-30/30A SCOUR VALVE CHAMBER AS PER IRISH

WATER STANDARD DETAIL STD-W-30 HYDRANTS AS PER IRISH WATER

STANDARD DETAIL STD-W-16/18 WASH OUT HYDRANT CHAMBER AS PER

IRISH WATER STANDARD STD-W-30A METER CHAMBER AS PER

IRISH WATER STANDARD STD-W-26 SCOUR VALVE CHAMBER AS PER

IRISH WATER STANDARD STD-W-26

0 5 10 15 20 25m

P01	ISSUED FOR PLANNING	FJVR	JB	02/09/24
REV	DESCRIPTION	BY	CHK/ APP	DATE

DIMENSIONS IN METRES

CAPAMI LTD

OLDCOURT LRD

DRAWING TITLE WATERMAIN LAYOUT SHEET 6 OF 6

CONSULTING ENGINEERS

GROSVENOR COURT, 67A PATRICK STREET, DUN LAOGHAIRE, COUNTY DUBLIN,

TELEPHONE: +353 1 2311041 NORWICH **W**ELWYN GARDEN CITY **L**ONDON **T** THE HAGUE **T** FRANKFURT

DRAWING STATUS								
PLANNING								
SCALE @ A1	DATE	DRAWN BY	CHECKED	APPROVED				
1:500	04/07/24	FJVR	JB	SOR				
ORG NO.	_			REV.				

P211102-PIN-XX-XX-DR-C-00306-S2